



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

November 7, 2008

Mr. Lonnie Thibodeaux
Interim Water Utilities Director
City of Oceanside
300 North Coast Highway
Oceanside, CA 92054

In reply refer to:
NCGW:255386:cprowell

Dear Mr. Thibodeaux:

SUBJECT: REVIEW OF MONITORING REPORTS FOR ORDER NO. 93-07, LAND DISPOSAL OF WASTEWATER, SAN LUIS REY WASTEWATER TREATMENT PLANT (Reference NCGW:255386:cprowell)



The California Regional Water Quality Control Board, San Diego Region (Regional Board) has completed review of the following monitoring reports covering the reporting period from July 2008 through September 2008:

MONITORING REPORTS REVIEWED FOR ORDER NO. 98-04			
FREQUENCY	PERIOD	REPORT DATE	DATE RECEIVED
Monthly:	September 2008	October 23, 2008	October 29, 2008
Quarterly Self-Monitoring Report	July – September 2008	October 23, 2008	October 29, 2008
Quarterly Reclaimed Water Users Report	July – September 2008	October 9, 2008	October 14, 2008

The Regional Board has reviewed the above referenced reports and has the following comment:

- Daily flow from secondary facilities. Discharge Specification B.2 limits the flow from secondary facilities to a maximum of 10.7 million gallons per day (MGD). The daily flow from the secondary facilities was reported as 10.8 MG on September 18, 2008, violates the discharge specifications. The City of Oceanside notified the Regional Board of upgrades to the San Luis Rey Waste Water Treatment Plant in a letter dated July 26, 2006. In addition, the Regional Board understands that additional upgrades are planned for the future. A new Report of Waste Discharge should be submitted to the Regional Board pursuant to Reporting Requirement E.1.d and E.1.f, so that the Regional Board can evaluate the need to amend Order 93-07.

California Environmental Protection Agency



Mr. Lonnie Thibodeaux, Interim Water Utilities Director
City of Oceanside


November 7, 2008

The October 2008 monthly monitoring report is due on or before November 30, 2008.

The heading portion of this letter includes a Regional Board code number noted after "In reply refer to:" In order to assist us in the processing of your correspondence please include this code number in the heading or subject line portion of all correspondence and reports to the Regional Board pertaining to this matter.

If you have any questions regarding the above, please contact Ms. Cheryl Prowell at (858) 467-2745 or cprowell@waterboards.ca.gov.

Respectfully,



JOHN R. ODERMATT, Senior Engineering Geologist
Northern San Diego County Groundwater Unit

JRO:clp

CIWQS DATABASE:

Reg Measure -355019
Party ID - 32485
Place ID - 255386
Person ID -299830
Violation ID - 793084